

Fire Protection Survey Services™

P.O. Box 170
Longford Mills, Ontario, Canada, L0K 1L0
Telephone: (249) 359-7231 Fax: (208) 474-3520
E-mail: fpss@explornet.ca Website: www.fpss.ca

Fire Department Water Tanker Shuttle Accreditation

Presented To: Guelph/Eramosa Township

ACCREDITED FIRE STATIONS

Rockwood Fire Station (6)

Date Test Passed: December 3rd, 2016

Flow Achieved: 625 I.G.P.M. 2840 LITERS/MIN.

Two (2) Hour Test Time



Signed: Peter J. Rose ~

Peter J. Rose, C.E.T., F.P.T.
Senior Partner
Senior Fire Protection Specialist
Senior Loss Control Specialist

This Certificate Expires on January 1, 2022