

2024 Municipal Sewage Collection System Annual Report

4.6 of the Rockwood CLI-ECA 104-W601

Prepared by:

Guelph-Eramosa Township



March 31, 2025

I. Introduction

Purpose

The purpose of this report is to satisfy the requirements of Schedule E, Section 4.6 of the Environmental Compliance Approval for a Municipal Sewage Collection System that has been issued to the Township of Guelph/Eramosa by the Ontario Ministry of Environment, Conservation and Parks (MECP).

Scope

This report covers the period from January 1 to December 31, 2024 for the following municipally owned and operated wastewater collection system.

Wastewater Collection System Information

ECA Number	104-W601
Issue Number	1
System Name	Rockwood Sewage Collection System
ECA Issue Date	May 29, 2024

Report Content

Under Schedule E, Section 4.6 CLI-ECA 104-W601, the Owner of the municipal sewage collection system is required to prepare an annual performance report covering the period of January 1 to December 31 by March 31st of the following year. The report is to be submitted to the MECP Director and if a collection system overflow or spill of sewage occurred during the reporting period it will also be submitted to the District Manager. The annual performance report must contain the following information:

- If applicable, includes a summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized System or system operations.
- A summary of any operating problems encountered, and corrective actions taken.
- A summary of all calibration, maintenance, and repairs carried out on any major structure, equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System.
- A summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.

- A summary of all Alterations to the Authorized System within the reporting period that are authorized by this approval include a list of Alterations that pose a Significant Drinking Water Threat.
- A summary of all Collection System Overflow(s) and Spill(s) of Sewage including:
 - Dates.
 - Volumes and durations.
 - If applicable, loadings for total suspended solids, BOD, total phosphorus, and total Kjeldahl nitrogen, and sampling results for E.coli;
 - Disinfection, if any; and
 - Any adverse impact(s) and any corrective actions, if applicable.
- A summary of efforts made to reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses, including the following items, as applicable:
 - A description of projects undertaken and completed in the Authorized System that result in overall overflow reduction or elimination including expenditures and proposed projects to eliminate overflows with estimated budget forecast for the year following that for which the report is submitted.
 - Details of the establishment and maintenance of a **Pollution Prevention and Control Plan or (PPCP)** including a summary of
 - project progresses compared to the PPCP's timelines.
 - An assessment of the effectiveness of each action taken.
 - An assessment of the ability to meet **Procedure F-5-1** (set by the Ministry of Environment, Conservation and Parks) the objectives (as applicable) and if able to meet the objectives, an overview of next steps and estimated timelines to meet the objectives.
 - Public reporting approach, including proactive efforts.

Report Format

This report provides details on measures taken by staff to ensure compliance with Terms and Conditions of the control documents, Act, Regulations, or any orders the system may have been under during the reporting period.

Report Availability

A copy of this report is available for viewing at the Township of Guelph/Eramosa, 8348 Wellington Rd. 124, Rockwood and Online at www.get.on.ca

As per the Accessibility for Ontarians with Disabilities Act (AODA), this document is available in an alternate format by e-mailing the Township stutt@get.on.ca or by calling 519-856-9596

Table of Contents

I. Introduction.....	1
Table of Contents.....	4
1.0 System Description.....	1
2.0 Gazer Mooney Wastewater Collection System.....	1
3.0 Monitoring Data	2
4.0 Operating Problems Encountered and Corrective Actions	4
5.0 Calibration, Maintenance and Repairs.....	5
Table 3: Sewage Pumping Station Maintenance and Repairs	5
6.0 Complaints.....	5
7.0 Alterations to the Authorized System within the reporting period that are authorized by this approval including a list of Alterations that pose a Significant Drinking Water Threat.....	6
8.0 Collection System Overflow(s) and Spill(s) of Sewage	6
9.0 Efforts to Reduce Collection System Overflows, Spills, STP Overflows and STP Bypasses....	6
Appendix A – Calibration Reports	7

List of Tables

Table 1: Sewage Flow Monitoring Summary.....	2
Table 2: Sewage Flow – 5 Year Trend.....	3
Table 3: Sewage Pumping Station Maintenance and Repairs	5

1.0 System Description

Rockwood Wastewater Collection System

The Rockwood Sewage Collection System consists of a gravity sanitary collection system, 5 sewage pumping stations and associated forcemains, a pre-treatment plant with 6500 meters of forcemain which conveys the sewage from the Alma Street Pre-treatment Transfer Station to the City of Guelph.

Four of the 5 sewage pumping stations service approximately two-thirds of the Village. Wastewater flows being collected at Lou's Blvd., Mill Run, and Ridge Road Sewage Pumping Stations. The Valley Road Sewage Pumping Station (SPS) collects wastewater from these three (3) SPS and from a gravity portion of the sanitary sewer network. From the north, existing gravity sanitary sewer system is conveyed to Alma pre-treatment transfer station.

There are 0 trunk sewers, 0 partially separate sewers, 0 nominally separate sewers, 0 kilometers of combined sewers, and 0 wet-weather interceptor tanks.

Alma Street Sewage Pre-Treatment Plant

Hwy 7 [300] mm in diameter and [6500] meters discharging to a City of Guelph manhole near Skyway Drive.

Valley Road Sewage Pumping Station

355 meters of 300 mm diameter forcemain from the pumping station to Guelph Street. 660 metres of 250 mm diameter forcemain from Guelph Street to a manhole on Alma Street [MH 98] discharging by gravity sewer to the Alma Street Pre-Treatment Facility.

Lou's Blvd., Sewage Pumping Station

290 metres of 100 mm diameter forcemain entering MH 426 on Lou's Blvd.

Mill Run Sewage Pumping Station

700 metres of 150 mm diameter forcemain entering MH 426 on Lou's Blvd.

Ridge Road Sewage Pumping Station

157 metres of 138 mm diameter forcemain entering MH # 701 on Main St (Hwy 7).

2.0 Gazer Mooney Wastewater Collection System

The Gazer Sewage Pumping Station (SPS) has approximately 72 service connections, 442 meters of 100 mm diameter forcemain entering City Manhole #718 on Speedvale Ave. The approximate population is 216 residents.

The system is operated by the City of Guelph by a legal agreement that was last signed by representatives of the City of Guelph and the Township of Guelph/Eramosa on August 7, 2012.

3.0 Monitoring Data

Rockwood (Jan. 01 to Dec. 31, 2024)


Table 1: Sewage Flow Monitoring Summary

2024	Alma Transfer Station Total Flow to Guelph (m3)	Valley SPS Total Flow (m3)	Percent Volume from Valley to Alma (%)	Average Daily Flow (m ³)	Maximum Daily Flow (m ³)	Max Allowable Daily Flow to Guelph (m3/day)
January	40,062.0	27,234.4	14%	1292.3	2049.6	2360.0
February	36,239.6	23,825.0	14%	1249.6	1521.0	2506.7
March	40,493.2	27,026.3	13%	1306.2	1603.5	2915.0
April	45,774.9	28,964.0	12%	1525.8	1945.2	2949.6
May	43,527.7	26,156.0	13%	1404.1	1623.9	2508.5
June	36,499.3	23,672.3	14%	1216.6	1440.0	2197.0
July	39,560.5	24,829.6	14%	1276.1	1782.2	2126.0
August	33,161.3	21,264.9	15%	1069.7	1196.6	2090.2
September	31,426.7	20,498.4	17%	1047.6	1183.5	2108.1
October	29,234.6	19,195.2	22%	943.1	2049.6	2184.8
November	31,120.8	20,892.2	17%	1037.4	1227.8	2185.7
December	35,440.3	24,051.1	15%	1143.2	1374.3	2398.3

SPS – Sewage Pumping Station

Table 2: Sewage Flow – 5 Year Trend

Month	2020 Sewage Flow m3	2021 Sewage Flow m3	2022 Sewage Flow m3	2023 Sewage Flow m3	2024 Sewage Flow m3
January	51,122.6	34,994.3	35,213.8	39,476.9	40,062.0
February	33,858.3	30,847.1	35,601.6	38,534.9	36,239.6
March	45,297.0	38,071.9	50,875.5	46,920.5	40,493.2
April	39,223.3	34,589.7	40,846.3	55,698.2	45,774.9
May	36,053.2	33,681.9	37,224.7	45,737.2	43,527.7
June	31,770.1	31,364.9	32,522.0	34,976.2	36,499.3
July	32,704.9	32,156.1	31,080.5	35,622.3	39,560.5
August	31,832.1	30,859.6	30,951.2	35,381.3	33,161.3
September	30,529.8	32,254.7	30,353.9	32,255.9	31,426.7
October	31,881.3	35,688.2	33,100.5	32,802.6	29,234.6
November	31,242.9	33,419.3	33,737.3	31,201.8	31,120.8
December	35,023.4	39,182.4	37,670.7	34,669.9	35,440.3



4.0 Operating Problems Encountered and Corrective Actions

- To reduce clogging and build up within the wet well, flush valves were installed on each wet well.
- Deficiencies and problem areas found during CCTV camera of the north end of Rockwood are considered in the planning and design process for the area and Water/Wastewater Rate Study and Financial Plan for the system.

5.0 Calibration, Maintenance and Repairs

Table 3: Sewage Pumping Station Maintenance and Repairs

Rockwood Sewage Pumping Stations (SPS)	
Maintenance Activity / Expenditure	Location
123 manholes were inspected and flushed/cleaned	Central and north end of Rockwood
3522.1 m of sewer main was flushed	North end of Rockwood
3522.1 m of sewer main was inspected with CCTV	North end of Rockwood
Weekday checks at facility SPS (sewage pumping stations) and daily checks at Alma Transfer Station.	All locations
SCADA upgrades	All locations
Disconnected Monitoring from SCADA and began to manually track data	Skyway
Sewage pump replacement	Lou's SPS
Repair /troubleshoot issues with pump #2	Mill Run SPS
Water service line repair	Ridge SPS
calibrations of CO detector	Rockmosa SPS
O2 sensor replacement	Alma TS
Calibrations of gas monitoring devices	Alma TS
Grit removal	Alma TS
*Calibrations of flow meters – attached end of report	all locations
Replacement of pressure transducer	Valley SPS
Generator inspections semi and annual	all locations
Generator repairs	Valley SPS
	Lou's SPS
Davit lift repairs	Valley SPS
	Rockmosa SPS
Cleaning of wet wells	Mill Run SPS
	Lou's SPS
	Ridge SPS
	Valley SPS
	Alma TS
Backflow Inspections	Ridge SPS
	Rockmosa SPS

SPS = Sewage Pumping Station

TS=Transfer Station

* Attached report

6.0 Complaints

No public complaints during this reporting period.

7.0 Alterations to the Authorized System within the reporting period that are authorized by this approval including a list of Alterations that pose a Significant Drinking Water Threat.

No alterations to the authorized system during this reporting period.

8.0 Collection System Overflow(s) and Spill(s) of Sewage

No sewage collection system overflows or spills during this reporting period.

9.0 Efforts to Reduce Collection System Overflows, Spills, STP Overflows and STP Bypasses.

There are no issues with the collection system.

Appendix A – Calibration Reports

Certificate of Calibration

Flow Meter



595758 Hwy 59 North RR6
Woodstock, ON. N4S 7W1
Ph#: 519-535-9835
Email: Jfranssen@jbfcontrols.com

☒ Verification
☐ Calibration

Calibration Date: October 22, 2024
Due Date: **October 22, 2025**

Client Information
Guelph/Eramosa Township
8348 Wellington Rd 124
Rockwood, Ontario, N0B 2K0

SCADA Reading Confirmation		
Instrument	SCADA	% Deviation
0.000	0.000	0.000%

Project: GET202001	Description: SPS Flow	Pipe Size: 10"
Client: Guelph/Eramosa TWP	Make: ABB	Pipe Material: Stainless Steel
Client Contact: Jason Jones	Model: Magmaster	K-Factor: 242280341X002_290114
Facility: Valley Road SPS	Controller S/N: 242280341/Y001	Range: 0 to 100
Technician: Jeremy Franssen	Sensor S/N: 08546196	Units: L/S
Application: Water	Tag Number: FIT 101	Accuracy: 0.50% Reading

mA Output					
Reference: mA	As Found: mA	% Deviation	As Left: mA	% Deviation	PASS/FAIL
4.000	4.000	0.000%	4.000	0.000%	PASS
8.000	7.999	0.006%	7.999	0.006%	PASS
12.000	11.999	0.006%	11.999	0.006%	PASS
16.000	16.000	0.000%	16.000	0.000%	PASS
20.000	20.001	0.006%	20.001	0.006%	PASS

Flow Rate Output					
Reference: L/S	As Found: L/S	% Deviation	As Left: L/S	% Deviation	PASS/FAIL
0.000	0.000	0.000%	0.000	0.000%	PASS
25.000	24.994	0.006%	24.994	0.006%	PASS
50.000	49.994	0.006%	49.994	0.006%	PASS
75.000	75.000	0.000%	75.000	0.000%	PASS
100.000	100.006	0.006%	100.006	0.006%	PASS

Remarks:
Verification of Flow Meter Parameters. Confirm, OK.
Verification of 4-20 mA Output, Confirm, OK.
Verification of Instrument to SCADA Readings, Confirm, OK.
Cleaned and Certified
Totalizer Reading: 3055958.18m3

Calibration Standards Used				
Description	Serial n°	Certificate n°	Calibration Date	Due Date
Fluke 705 Loop Calibrator	4624185	57113-B	March 2024	March 2025

Calibration standards used in the certificate are traceable to the National Institute of Standards and Technology (NIST).

Service Technician: Jeremy Franssen
Signature

Certificate of Calibration

Flow Meter



595758 Hwy 59 North RR6
Woodstock, ON. N4S 7W1
Ph#: 519-535-9835
Email: Jfranssen@jbfcontrols.com

☒ Verification
☐ Calibration

Calibration Date: October 22, 2024
Due Date: **October 22, 2025**

Client Information
Guelph/Eramosa Township
8348 Wellington Rd 124
Rockwood, Ontario, N0B 2K0

SCADA Reading Confirmation		
Instrument	SCADA	% Deviation
0.000	0.000	0.000%

Project: GET202001	Description: To Guelph	Pipe Size: 12"
Client: Guelph/Eramosa TWP	Make: Endress & Hauser	Pipe Material: Stainless Steel
Client Contact: Jason Jones	Model: Promag 400	K-Factor: 1.3681
Facility: Alma Street WWTP	Controller S/N: L80ACE19000	Range: 0 to 80
Technician: Jeremy Franssen	Sensor S/N: L80ACE19000	Units: L/S
Application: Water	Tag Number: FIT 401	Accuracy: 0.50% Reading

mA Output					
Reference: mA	As Found: mA	% Deviation	As Left: mA	% Deviation	PASS/FAIL
4.000	4.004	0.025%	4.004	0.025%	PASS
8.000	8.005	0.031%	8.005	0.031%	PASS
12.000	12.005	0.031%	12.005	0.031%	PASS
16.000	16.006	0.038%	16.006	0.038%	PASS
20.000	20.006	0.038%	20.006	0.038%	PASS

Flow Rate Output					
Reference: L/S	As Found: L/S	% Deviation	As Left: L/S	% Deviation	PASS/FAIL
0.000	0.020	0.025%	0.020	0.025%	PASS
20.000	20.025	0.031%	20.025	0.031%	PASS
40.000	40.025	0.031%	40.025	0.031%	PASS
60.000	60.030	0.038%	60.030	0.038%	PASS
80.000	80.030	0.038%	80.030	0.038%	PASS

Remarks:
Verification of Flow Meter Parameters. Confirm, OK.
Verification of 4-20 mA Output, Confirm, OK.
Verification of Instrument to SCADA Readings, Confirm, OK.
Cleaned and Certified
Totalizer Reading: 3076790.25m3

Calibration Standards Used				
Description	Serial n°	Certificate n°	Calibration Date	Due Date
Fluke 705 Loop Calibrator	4624185	57113-B	March 2024	March 2025

Calibration standards used in the certificate are traceable to the National Institute of Standards and Technology (NIST).

Service Technician: Jeremy Franssen
Signature

Certificate of Calibration

Flow Meter



595758 Hwy 59 North RR6
Woodstock, ON. N4S 7W1
Ph#: 519-535-9835
Email: Jfranssen@jbfccontrols.com

☒ Verification
☐ Calibration

Calibration Date: October 22, 2024
Due Date: **October 22, 2025**

Client Information
Guelph/Eramosa Township
8348 Wellington Rd 124
Rockwood, Ontario, N0B 2K0

SCADA Reading Confirmation		
Instrument	SCADA	% Deviation
0.000	0.000	0.000%

Project: GET202001	Description: To/From EQ Tank	Pipe Size: 12"
Client: Guelph/Eramosa TWP	Make: Endress & Hauser	Pipe Material: Stainless Steel
Client Contact: Jason Jones	Model: Promag 400	K-Factor: 1.3300
Facility: Alma Street WWTP	Controller S/N: L80ACD19000	Range: 0 to 200
Technician: Jeremy Franssen	Sensor S/N: L80ACD19000	Units: L/S
Application: Water	Tag Number: FIT 402	Accuracy: 0.50% Reading

mA Output					
Reference: mA	As Found: mA	% Deviation	As Left: mA	% Deviation	PASS/FAIL
4.000	4.004	0.025%	4.004	0.025%	PASS
8.000	8.005	0.031%	8.005	0.031%	PASS
12.000	12.005	0.031%	12.005	0.031%	PASS
16.000	16.006	0.038%	16.006	0.038%	PASS
20.000	20.007	0.044%	20.007	0.044%	PASS

Flow Rate Output					
Reference: L/S	As Found: L/S	% Deviation	As Left: L/S	% Deviation	PASS/FAIL
0.000	0.050	0.025%	0.050	0.025%	PASS
50.000	50.063	0.031%	50.063	0.031%	PASS
100.000	100.063	0.031%	100.063	0.031%	PASS
150.000	150.075	0.037%	150.075	0.037%	PASS
200.000	200.088	0.044%	200.088	0.044%	PASS

Remarks:
Verification of Flow Meter Parameters. Confirm, OK.
Verification of 4-20 mA Output, Confirm, OK.
Verification of Instrument to SCADA Readings, Confirm, OK.
Cleaned and Certified
Totalizer Reading: 1845.70m3

Calibration Standards Used				
Description	Serial n°	Certificate n°	Calibration Date	Due Date
Fluke 705 Loop Calibrator	4624185	57113-B	March 2024	March 2025

Calibration standards used in the certificate are traceable to the National Institute of Standards and Technology (NIST).

Service Technician: Jeremy Franssen
Signature

Certificate of Calibration

Flow Meter



595758 Hwy 59 North RR6
Woodstock, ON. N4S 7W1
Ph#: 519-535-9835
Email: Jfranssen@jbfccontrols.com

☒ Verification
☐ Calibration

Calibration Date: October 23, 2024
Due Date: **October 23, 2025**

Client Information
Guelph/Eramosa Township
8348 Wellington Rd 124
Rockwood, Ontario, N0B 2K0

SCADA Reading Confirmation		
Instrument	SCADA	% Deviation
16.500	16.500	0.000%

Project: GET202001	Description: Station Flow	Pipe Size: 12"
Client: Guelph/Eramosa TWP	Make: Endress & Hauser	Pipe Material: Stainless Steel
Client Contact: Jason Jones	Model: Promag 10	K-Factor: 1.2796
Facility: Skyway Meter Station	Controller S/N: J6082A16000	Range: 0 to 150
Technician: Jeremy Franssen	Sensor S/N: J6082A16000	Units: L/S
Application: Water	Tag Number: FIT 101	Accuracy: 0.50% Reading

mA Output					
Reference: mA	As Found: mA	% Deviation	As Left: mA	% Deviation	PASS/FAIL
4.000	4.003	0.075%	4.003	0.075%	PASS
8.000	8.009	0.113%	8.009	0.113%	PASS
12.000	12.015	0.125%	12.015	0.125%	PASS
16.000	16.021	0.131%	16.021	0.131%	PASS
20.000	20.029	0.145%	20.029	0.145%	PASS

Flow Rate Output					
Reference: L/S	As Found: L/S	% Deviation	As Left: L/S	% Deviation	PASS/FAIL
0.000	0.028	0.019%	0.028	0.019%	PASS
37.500	37.584	0.225%	37.584	0.225%	PASS
75.000	75.141	0.188%	75.141	0.188%	PASS
112.500	112.697	0.175%	112.697	0.175%	PASS
150.000	150.272	0.181%	150.272	0.181%	PASS

Remarks:
Verification of Flow Meter Parameters. Confirm, OK.
Verification of 4-20 mA Output, Confirm, OK.
Verification of Instrument to SCADA Readings, Confirm, OK.
Cleaned and Certified
Totalizer Reading: 4437062m3

Calibration Standards Used				
Description	Serial n°	Certificate n°	Calibration Date	Due Date
Fluke 705 Loop Calibrator	4624185	57113-B	March 2024	March 2025

Calibration standards used in the certificate are traceable to the National Institute of Standards and Technology (NIST).

Service Technician: Jeremy Franssen
Signature